

## **ADDRESSABLE MANUAL CALL POINT 1Q500**

The IQ500 series Manual Call Point is compliant with latest standards and is designed to interface With Fireprotect make addressable fire alarm panel.DIP switches are provided for addressing of the call point. The RED blinking LED indicates normal operating condition. Activation of MCP is indicated by RED steady LED, and also a visible YELLOW BLACK strip.

#### **Features:**

- EN54-11 Approved Type A Indoor Use.
- Re-Settable by an element kit.
- Suitable for flush or surface mounting
- Module Addressing by 8 way DIP Switches.
- Low Standby Current.

# **Mechanical Specification:**

Temperature : 0-49°C.
Relative Humidity : 0-93%
Connection : 2.5mm²
IP Rating : IP 53



# **Electrical Specification:**

Operating Voltage : 24VDC.

Power-up surge current : 0.8mA

Quiescent Current : 0.5mA.

Alarm Current : 5.8mA

### **Wiring Diagram**

	L1		L1	L1		L1
LOOP	L2	MCP	L2	L2	MCP	L2

Note: L1 and L2 are polarity insensitive, but for the sake of consistency. It's recommend the L2 kept negative